




Rainy River District School Board
ATTN: Rainy River District School Board
Re: North Star Community School
522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Date Received: 29-JUL-16
Report Date: 08-AUG-16 14:03 (MT)
Version: FINAL

Client Phone: 807-275-6762

Certificate of Analysis

Lab Work Order #: L1806280
Project P.O. #: NOT SUBMITTED
Job Reference: 500045683
C of C Numbers:
Legal Site Desc:



Christina Shepherd
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1081 Barton Street, Thunder Bay, ON P7B 5N3 Canada | Phone: +1 807 623 6463 | Fax: +1 807 623 7598
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

CRITERIA REPORT

L1806280 CONTD....

Page 2 of 3

08-AUG-16 14:04:58

500045683

Sample Details/Parameters	Result	Qualifier	D.L.	Units	Criteria Specific Limits	Analyzed	Batch
L1806280-1 ~P1 BOTTLE 1 ROOM 146 Sampled By: TD on 18-JUN-16 @ 06:05 Matrix: Plumbing Standing Lead per Ont. DW Regulation 243 Lead (Pb)-Total	18.3		1.0	ug/L	ON-DWSTANDARD <hr/> ** 10	07-AUG-16	R3519632
L1806280-2 ~P2 BOTTLE 2 ROOM 146 Sampled By: TD on 18-JUN-16 @ 06:40 Matrix: Plumbing Flushed Lead per Ont. DW Regulation 243 Lead (Pb)-Total	<1.0		1.0	ug/L	ON-DWSTANDARD <hr/> 10	07-AUG-16	R3519632

* Detection Limit for result exceeds Criteria Specific Limit. Assessment against Criteria Limit cannot be made.

** Analytical result for this parameter exceeds Criteria Specific Limit listed on this report.

Reference Information

500045683

L1806280 CONTD....

Page 3 of 3

08-AUG-16 14:04:58

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Preparation Method Reference(Based On)	Analytical Method Reference(Based On)
MET-DW-MS-TB	Water	Drinking Water Metals		APHA 3030E/EPA 6020A

Instrumental analysis is by inductively coupled plasma - mass spectrometry (EPA Method 6020A).

Laboratory Methods employed follow in-house procedures, which are generally based on nationally or internationally accepted methodologies.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
TB	ALS ENVIRONMENTAL - THUNDER BAY, ONTARIO, CANADA		

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of criteria limits is provided as is without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information.



Environmental

Quality Control Report

Workorder: L1806280

Report Date: 08-AUG-16

Page 1 of 2

Client: Rainy River District School Board
Re: North Star Community School 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Contact: Rainy River District School Board

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
MET-DW-MS-TB								
	Water							
Batch	R3519632							
WG2360746-8	DUP	L1805952-2						
Lead (Pb)-Total		<1.0	<1.0	RPD-NA	ug/L	N/A	20	07-AUG-16
WG2360746-6	LCS							
Lead (Pb)-Total			100.4		%		80-120	07-AUG-16
WG2360746-5	MB							
Lead (Pb)-Total			<1.0		ug/L		1	07-AUG-16
WG2360746-7	MS	L1805952-2						
Lead (Pb)-Total			99.2		%		70-130	07-AUG-16

Quality Control Report

Workorder: L1806280

Report Date: 08-AUG-16

Client: Rainy River District School Board
Re: North Star Community School 522 2ND ST EAST
FORT FRANCES ON P9A 1N4
Contact: Rainy River District School Board

Page 2 of 2

Legend:

Limit ALS Control Limit (Data Quality Objectives)
DUP Duplicate
RPD Relative Percent Difference
N/A Not Available
LCS Laboratory Control Sample
SRM Standard Reference Material
MS Matrix Spike
MSD Matrix Spike Duplicate
ADE Average Desorption Efficiency
MB Method Blank
IRM Internal Reference Material
CRM Certified Reference Material
CCV Continuing Calibration Verification
CVS Calibration Verification Standard
LCSD Laboratory Control Sample Duplicate

Sample Parameter Qualifier Definitions:

Qualifier	Description
RPD-NA	Relative Percent Difference Not Available due to result(s) being less than detection limit.

Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



L1806280-COFC

DRINKING WATER CHAIN OF CUSTODY

PLEASE CIRCLE APPLICABLE REGULATION:

Reg 170/03 Reg 318/08 319/08 **Reg 243** C of A

Is this a resample from an adverse water quality incident? Yes No

ALS Thunder Bay, 1081 Barton Street. Thunder Bay, ON P7B 5N3
Ph: 807-623-6463 Fax: 807-623-7598 Toll-Free 1-800-668-9878

WORKS NAME		WORKS PHONE		ANALYSES REQUESTED												FOR LAB USE ONLY				
RRDSB - North Star Community School		School: 807-597-6640 Sherrri: 807-275-4979		Please indicate test for each sample by Checkmark in the box below												SUBMISSION NO. L1806280				
CLIENT CONTACT NAME		WORKS FAX		Total Coliform/E. coli (TC/EC)	Het. Plate Count (HPC)	Nitrate/Nitrite	THM (Max. Res. Time)	Sched 23 Inorganics	Sched 24 Organics	Sodium	Fluoride	Turbidity	Lead	Alkalinity	Other:	Field pH	LOGGED BY MM			
Peter Gardiman		School: 807-597-5810 Admin: 807-274-5078															DATE 29 June 16			
WORKS ADDRESS(physical)		AFTER HOURS PHONE															TIME 5:55 pm			
209 Hawthorne Road, Atikokan, ON, P0T 1C0		Peter: 807-275-6762 Todd: 807-597-7801 Travis: 807-276-4733		HEALTH UNIT														TEMPERATURE AT RECEIPT (C) 5.9		
REPORTING ADDRESS		HEALTH UNIT																		
522 Second St. E., Fort Frances, ON, P9A 1N4		NWDHU																		
WORKS/DWIS/SDWS NUMBER		HEALTH UNIT																		
500045683		Kenora: 807-468-3147/807-468-3914 Fort Frances: 807-274-9827/807-274-0779																		
EMAIL: sherrri.belluz@mail.rrdsb.com peter.gardiman@mail.rrdsb.com		Requested Service (Circle One)																		
		<input checked="" type="radio"/> Reg <input type="radio"/> Pri (50%) <input type="radio"/> Emerg (100%)																		
SAMPLE DESCRIPTION		Chlorine Residual mg/L	Sample Date	Sample Time	Regulated Sample Type* (R,T,D,P, PS,PF)													pH <2	Volume 1L	Time Check
(This description will appear on the report)																				
BOTTLE #1 Room 146		/	JUNE 18	6:05 AM	PS													✓	✓	✓
BOTTLE #2 Room 146		/	JUNE 18	6:40 AM	PF													✓	✓	✓

SD
SD

* Sample Type Legend: R - Raw Water T - Treated Source D - Distribution Sample P - Plumbing PS - Plumbing Standing PF - Plumbing Flushed

SAMPLED BY (PRINT): T. DESAULNIERS	SAMPLED BY (SIGNATURE): <i>T. Desaulniers</i>	DATE/TIME RECEIVED AT LAB: 7-29-16 1:32 PM	Other Comments/Cautions (Please identify known or suspected hazards) LOG SHOWS NOBODY IN BUILDING FOR PAST 6 HRS	CHECK TO LIST ON REPORT
SUBMITTED TO LAB BY (PRINT): T. DESAULNIERS	SUBMITTED TO LAB BY (SIGNATURE): <i>T. Desaulniers</i>	RECEIVED AT LAB BY: TK		Chlorine Residual(s)