




Rainy River District School Board  
ATTN: Rainy River District School Board  
Nestor Falls School  
522 2ND ST. EAST  
FORT FRANCES ON P9A 1N4

Date Received: 26-SEP-17  
Report Date: 13-OCT-17 14:41 (MT)  
Version: FINAL

Client Phone: 807-275-6762

## Certificate of Analysis

Lab Work Order #: L1997349  
Project P.O. #: NOT SUBMITTED  
Job Reference: RRDSB - NESTOR FALLS SCHOOL  
C of C Numbers:  
Legal Site Desc:

  
\_\_\_\_\_  
Christina Shepherd  
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1081 Barton Street, Thunder Bay, ON P7B 5N3 Canada | Phone: +1 807 623 6463 | Fax: +1 807 623 7598  
ALS CANADA LTD Part of the ALS Group An ALS Limited Company



# ANALYTICAL GUIDELINE REPORT

RRDSB - NESTOR FALLS SCHOOL

Sample Details		Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits	
Grouping	Analyte						#1	#2
L1997349-1	RAW MECH ROOM							
Sampled By: CLIENT on 25-SEP-17 @ 11:45								
Matrix: WATER								
<b>Physical Tests</b>								
Color, True		20.8		2.0	CU	26-SEP-17		
Hardness (as CaCO3)		117	HTC	2.4	mg/L	13-OCT-17	*80-100	
pH		7.51		0.10	pH	28-SEP-17	6.5-8.5	
Total Suspended Solids		<2.0		2.0	mg/L	28-SEP-17		
UV Transmittance		64.8		1.0	% T	26-SEP-17		
<b>Anions and Nutrients</b>								
Ammonia, Total (as N)		0.133		0.020	mg/L	28-SEP-17		
Chloride (Cl)		2.27	SFT	0.10	mg/L	28-SEP-17		250
Nitrate and Nitrite as N		<0.040		0.040	mg/L	29-SEP-17	10.0	
Nitrate (as N)		0.021	SFT	0.020	mg/L	28-SEP-17	10	
Nitrite (as N)		<0.010	SFT	0.010	mg/L	28-SEP-17	1	
Organic Nitrogen		0.235		0.050	mg/L	28-SEP-17		*0.15
Total Kjeldahl Nitrogen		0.37		0.15	mg/L	28-SEP-17		
<b>Bacteriological Tests</b>								
Escherichia Coli		>2420		0	MPN/100m L	26-SEP-17	*0	
Heterotrophic Plate Count		>300		0	CFU/mL	26-SEP-17		
Total Coliforms		>2420		0	MPN/100m L	26-SEP-17	*0	
<b>Total Metals</b>								
Calcium (Ca)-Total		28.1		0.50	mg/L	28-SEP-17		
Iron (Fe)-Total		921		50	ug/L	28-SEP-17		*300
Magnesium (Mg)-Total		11.4		0.50	mg/L	28-SEP-17		
Manganese (Mn)-Total		48.0		1.0	ug/L	28-SEP-17		50
Sodium (Na)-Total		12.3		0.50	mg/L	28-SEP-17	20	200
L1997349-2	TREATED MECH ROOM							
Sampled By: CLIENT on 25-SEP-17 @ 11:45								
Matrix: WATER								
<b>Physical Tests</b>								
Color, True		8.5		2.0	CU	26-SEP-17		
Hardness (as CaCO3)		<2.4	HTC	2.4	mg/L	29-SEP-17	**80-100	
pH		8.11		0.10	pH	28-SEP-17	6.5-8.5	
Total Suspended Solids		<2.0		2.0	mg/L	28-SEP-17		
UV Transmittance		74.5		1.0	% T	26-SEP-17		
<b>Anions and Nutrients</b>								
Chloride (Cl)		14.4		0.10	mg/L	28-SEP-17		250
<b>Bacteriological Tests</b>								
Escherichia Coli		0		0	MPN/100m L	27-SEP-17	0	
Heterotrophic Plate Count		0		0	CFU/mL	26-SEP-17		
Total Coliforms		0		0	MPN/100m L	27-SEP-17	0	
<b>Total Metals</b>								
Calcium (Ca)-Total		<0.50		0.50	mg/L	28-SEP-17		
Iron (Fe)-Total		722		50	ug/L	28-SEP-17		*300

\*\* Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

\* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

**Ontario Drinking Water Regulation (ODWQS) JAN.1,2017 = [Suite] - ON-DW-STANDARD+GUIDELINES**

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2017)

#2: Ontario DW Aesthetic and Operational Guidelines



# ANALYTICAL GUIDELINE REPORT

RRDSB - NESTOR FALLS SCHOOL

Sample Details		Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits							
Grouping	Analyte						#1	#2						
L1997349-2	TREATED MECH ROOM													
Sampled By: CLIENT on 25-SEP-17 @ 11:45														
Matrix: WATER														
<b>Total Metals</b>														
	Magnesium (Mg)-Total	<0.50		0.50	mg/L	28-SEP-17								
	Manganese (Mn)-Total	28.0		1.0	ug/L	28-SEP-17		50						

\*\* Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

\* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

**Ontario Drinking Water Regulation (ODWQS) JAN.1,2017 = [Suite] - ON-DW-STANDARD+GUIDELINES**

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2017)

#2: Ontario DW Aesthetic and Operational Guidelines

## Reference Information

**Sample Parameter Qualifier key listed:**

Qualifier	Description
HTC	Hardness was calculated from Total Ca and/or Mg concentrations and may be biased high (dissolved Ca/Mg results unavailable).
SFT	Sample was filtered due to turbidity interference. Result reflects soluble analyte concentration.

**Methods Listed (if applicable):**

ALS Test Code	Matrix	Test Description	Method Reference***
CL-L-IC-N-TB	Water	Chloride in Water by IC (Low Level)	EPA 300.1 (mod)
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			
COLOUR-TB	Water	Colour, True	APHA 2120 C
True Colour in aqueous matrices is analyzed using colourimetric detection. This is determined by filtering a sample through a 0.45 micron membrane filter followed by analysis of the filtrate using a platinum-cobalt standard.			
ETL-N2N3-TB	Water	Calculate from NO <sub>2</sub> + NO <sub>3</sub>	Calculation
HARDNESS-CALC-TB	Water	Hardness (as CaCO <sub>3</sub> )	CALCULATION
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215B (modified)
Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.			
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215D (modified)
Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.			
MET-DW-MS-TB	Water	Drinking Water Metals	APHA 3030E/EPA 6020A
Instrumental analysis is by inductively coupled plasma - mass spectrometry (EPA Method 6020A).			
N-ORG-T-CALC-TB	Water	Total Organic Nitrogen	CALCULATION
NH3-DW-COL-TB	Water	Ammonia by Discrete Analyzer	APHA 4500-NH3 G. (modified)
Ammonia in aqueous matrices is analyzed using discrete analyzer with colourimetric detection.			
NO2-DW-IC-TB	Water	Nitrite in Water by IC	EPA 300.1 (mod)
Inorganic anions are analyzed by Ion Chromatography with conductivity and/or UV detection.			
NO3-DW-IC-TB	Water	Nitrate in Water by IC	EPA 300.1 (mod)
Anions in aqueous matrices are analyzed using ion chromatography with conductivity and/or UV absorbance detectors.			
PH-DW-TB	Water	pH	APHA 4500-H
This analysis is carried out using procedures adapted from APHA Method 4500-H "pH Value". The pH is determined in the laboratory using a pH electrode			
TC,EC-QT51-TB	Water	Total Coliform and E.coli	APHA 9223 B
This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.			
TC,EC-QT97-TB	Water	Total Coliform and E.coli	APHA 9223 B
This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.			
TKN-DW-COL-TB	Water	Total Kjeldahl Nitrogen	APHA 4500-Norg (modified)
Total Kjeldahl Nitrogen in aqueous matrices is analyzed using a discrete analyzer with colourimetric detection.			
TSS-TB	Water	Total Suspended Solids	APHA 2540 D (modified)
Aqueous matrices are analyzed using gravimetry			
UV-TRANS-TB	Water	Transmittance, UV (254 nm)	APHA 5910 B-Spectrophotometer
Test method is adapted from APHA Method 5910B. A sample is filtered through a 0.45 um filter and it's UV Transmittance is measured in a quartz cell at 254 nm and reported as % Transmittance. The analysis is carried out without pH adjustment.			

\*\*\* ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody numbers:

*The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:*

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
TB	ALS ENVIRONMENTAL - THUNDER BAY, ONTARIO, CANADA		

## Reference Information

### GLOSSARY OF REPORT TERMS

*Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.*

*mg/kg - milligrams per kilogram based on dry weight of sample*

*mg/kg wwt - milligrams per kilogram based on wet weight of sample*

*mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight*

*mg/L - unit of concentration based on volume, parts per million.*

*< - Less than.*

*D.L. - The reporting limit.*

*N/A - Result not available. Refer to qualifier code and definition for explanation.*

*Test results reported relate only to the samples as received by the laboratory.*

*UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.*

*Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.*

*Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information.*



### Quality Control Report

Workorder: L1997349

Report Date: 13-OCT-17

Page 1 of 4

Client: Rainy River District School Board  
Nestor Falls School 522 2ND ST. EAST  
FORT FRANCES ON P9A 1N4

Contact: Rainy River District School Board

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
<b>CL-L-IC-N-TB</b>		<b>Water</b>						
<b>Batch</b>	<b>R3840748</b>							
<b>WG2627464-12</b>	<b>DUP</b>	<b>L1998179-7</b>						
Chloride (Cl)		<0.10	<0.10	RPD-NA	mg/L	N/A	20	28-SEP-17
<b>WG2627464-10</b>	<b>LCS</b>							
Chloride (Cl)			103.4		%		90-110	28-SEP-17
<b>WG2627464-9</b>	<b>MB</b>							
Chloride (Cl)			<0.10		mg/L		0.1	28-SEP-17
<b>WG2627464-11</b>	<b>MS</b>	<b>L1998179-7</b>						
Chloride (Cl)			103.9		%		75-125	28-SEP-17
<b>COLOUR-TB</b>		<b>Water</b>						
<b>Batch</b>	<b>R3838670</b>							
<b>WG2625759-3</b>	<b>DUP</b>	<b>L1997349-1</b>						
Color, True		20.8	21.9		CU	5.3	20	26-SEP-17
<b>WG2625759-2</b>	<b>LCS</b>							
Color, True			103.2		%		85-115	26-SEP-17
<b>WG2625759-1</b>	<b>MB</b>							
Color, True			<2.0		CU		2	26-SEP-17
<b>HPC-PP-TB</b>		<b>Water</b>						
<b>Batch</b>	<b>R3840460</b>							
<b>WG2625690-2</b>	<b>DUP</b>	<b>L1997349-1</b>						
Heterotrophic Plate Count		>300	>300		CFU/mL	0.0	65	26-SEP-17
<b>WG2625690-1</b>	<b>MB</b>							
Heterotrophic Plate Count			0		CFU/mL		1	26-SEP-17
<b>MET-DW-MS-TB</b>		<b>Water</b>						
<b>Batch</b>	<b>R3840750</b>							
<b>WG2627423-3</b>	<b>DUP</b>	<b>L1997561-2</b>						
Calcium (Ca)-Total		14.9	15.1		mg/L	1.3	20	28-SEP-17
Iron (Fe)-Total		<50	<50	RPD-NA	ug/L	N/A	20	28-SEP-17
Magnesium (Mg)-Total		3.00	3.08		mg/L	2.7	20	28-SEP-17
Manganese (Mn)-Total		<1.0	<1.0	RPD-NA	ug/L	N/A	20	28-SEP-17
Sodium (Na)-Total		3.37	3.28		mg/L	2.8	20	28-SEP-17
<b>WG2627423-2</b>	<b>LCS</b>							
Calcium (Ca)-Total			103.1		%		80-120	28-SEP-17
Iron (Fe)-Total			106.4		%		80-120	28-SEP-17
Magnesium (Mg)-Total			102.7		%		80-120	28-SEP-17
Manganese (Mn)-Total			100.0		%		80-120	28-SEP-17
Sodium (Na)-Total			101.5		%		80-120	28-SEP-17



### Quality Control Report

Workorder: L1997349

Report Date: 13-OCT-17

Page 2 of 4

Client: Rainy River District School Board  
Nestor Falls School 522 2ND ST. EAST  
FORT FRANCES ON P9A 1N4

Contact: Rainy River District School Board

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
<b>MET-DW-MS-TB</b>								
	Water							
<b>Batch</b>	<b>R3840750</b>							
<b>WG2627423-1</b>	<b>MB</b>							
Calcium (Ca)-Total			<0.50		mg/L		0.5	28-SEP-17
Iron (Fe)-Total			<50		ug/L		50	28-SEP-17
Magnesium (Mg)-Total			<0.50		mg/L		0.5	28-SEP-17
Manganese (Mn)-Total			<1.0		ug/L		1	28-SEP-17
Sodium (Na)-Total			<0.50		mg/L		0.5	28-SEP-17
<b>WG2627423-4</b>	<b>MS</b>	<b>L1997561-2</b>						
Calcium (Ca)-Total			N/A	MS-B	%		-	28-SEP-17
Iron (Fe)-Total			97.8		%		70-130	28-SEP-17
Magnesium (Mg)-Total			N/A	MS-B	%		-	28-SEP-17
Manganese (Mn)-Total			97.3		%		70-130	28-SEP-17
Sodium (Na)-Total			N/A	MS-B	%		-	28-SEP-17
<b>NH3-DW-COL-TB</b>								
	Water							
<b>Batch</b>	<b>R3840146</b>							
<b>WG2627107-6</b>	<b>LCS</b>							
Ammonia, Total (as N)			95.7		%		85-115	28-SEP-17
<b>WG2627107-5</b>	<b>MB</b>							
Ammonia, Total (as N)			<0.020		mg/L		0.02	28-SEP-17
<b>NO2-DW-IC-TB</b>								
	Water							
<b>Batch</b>	<b>R3840748</b>							
<b>WG2627464-10</b>	<b>LCS</b>							
Nitrite (as N)			101.5		%		90-110	28-SEP-17
<b>WG2627464-9</b>	<b>MB</b>							
Nitrite (as N)			<0.010		mg/L		0.01	28-SEP-17
<b>NO3-DW-IC-TB</b>								
	Water							
<b>Batch</b>	<b>R3840748</b>							
<b>WG2627464-10</b>	<b>LCS</b>							
Nitrate (as N)			104.0		%		90-110	28-SEP-17
<b>WG2627464-9</b>	<b>MB</b>							
Nitrate (as N)			<0.020		mg/L		0.02	28-SEP-17
<b>PH-DW-TB</b>								
	Water							
<b>Batch</b>	<b>R3840524</b>							
<b>WG2627603-2</b>	<b>LCS</b>							
pH			6.01		pH		5.9-6.1	28-SEP-17
<b>TC,EC-QT51-TB</b>								
	Water							



### Quality Control Report

Workorder: L1997349

Report Date: 13-OCT-17

Page 3 of 4

Client: Rainy River District School Board  
 Nestor Falls School 522 2ND ST. EAST  
 FORT FRANCES ON P9A 1N4

Contact: Rainy River District School Board

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
<b>TC,EC-QT51-TB</b>	<b>Water</b>							
<b>Batch</b>	<b>R3839811</b>							
<b>WG2626024-1 MB</b>								
Total Coliforms			0		MPN/100mL		1	27-SEP-17
Escherichia Coli			0		MPN/100mL		1	27-SEP-17
<b>TC,EC-QT97-TB</b>	<b>Water</b>							
<b>Batch</b>	<b>R3839247</b>							
<b>WG2625771-2 DUP</b>		<b>L1997498-3</b>						
Total Coliforms		>2420	>2420		MPN/100mL	0.0	65	26-SEP-17
Escherichia Coli		123	137		MPN/100mL	11	65	26-SEP-17
<b>WG2625771-1 MB</b>								
Total Coliforms			0		MPN/100mL		1	26-SEP-17
Escherichia Coli			0		MPN/100mL		1	26-SEP-17
<b>TKN-DW-COL-TB</b>	<b>Water</b>							
<b>Batch</b>	<b>R3839917</b>							
<b>WG2626067-2 LCS</b>								
Total Kjeldahl Nitrogen			94.5		%		75-125	28-SEP-17
<b>WG2626067-1 MB</b>								
Total Kjeldahl Nitrogen			<0.15		mg/L		0.15	28-SEP-17
<b>TSS-TB</b>	<b>Water</b>							
<b>Batch</b>	<b>R3841438</b>							
<b>WG2627540-2 LCS</b>								
Total Suspended Solids			92.6		%		85-115	28-SEP-17
<b>WG2627540-1 MB</b>								
Total Suspended Solids			<2.0		mg/L		2	28-SEP-17
<b>UV-TRANS-TB</b>	<b>Water</b>							
<b>Batch</b>	<b>R3838582</b>							
<b>WG2625726-2 DUP</b>		<b>L1996565-1</b>						
UV Transmittance		83.0	83.2		% T	0.2	20	26-SEP-17
<b>WG2625726-3 IRM</b>		<b>BLANK</b>						
UV Transmittance			100.0		% T		99.5-100.5	26-SEP-17
<b>WG2625726-1 LCS</b>								
UV Transmittance			94.8		%		85-115	26-SEP-17



# Quality Control Report

Workorder: L1997349

Report Date: 13-OCT-17

Client: Rainy River District School Board  
Nestor Falls School 522 2ND ST. EAST  
FORT FRANCES ON P9A 1N4

Page 4 of 4

Contact: Rainy River District School Board

## Legend:

---

Limit ALS Control Limit (Data Quality Objectives)  
DUP Duplicate  
RPD Relative Percent Difference  
N/A Not Available  
LCS Laboratory Control Sample  
SRM Standard Reference Material  
MS Matrix Spike  
MSD Matrix Spike Duplicate  
ADE Average Desorption Efficiency  
MB Method Blank  
IRM Internal Reference Material  
CRM Certified Reference Material  
CCV Continuing Calibration Verification  
CVS Calibration Verification Standard  
LCSD Laboratory Control Sample Duplicate

## Sample Parameter Qualifier Definitions:

---

Qualifier	Description
MS-B	Matrix Spike recovery could not be accurately calculated due to high analyte background in sample.
RPD-NA	Relative Percent Difference Not Available due to result(s) being less than detection limit.

---

## Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

---

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



Chain of Custody (COC) / Analytical Request Form

Canada Toll Free: 1 800 668 9878



L1997349-COFC

COC Number: 15 -

Page of

www.alsglobal.com

Report To		Report Format / Distribution			Select Service Level Below - Please confirm all E&P TATs with your AM - surcharges will apply												
Company: Rainy River District School Board		Select Report Format: <input checked="" type="checkbox"/> PDF <input type="checkbox"/> EXCEL <input type="checkbox"/> EDD (DIGITAL)			Regular [R] <input checked="" type="checkbox"/> Standard TAT if received by 3 pm - business days - no surcharges apply												
Contact: Peter Gardiman		Quality Control (QC) Report with Report <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO			4 day [P4] <input type="checkbox"/>		3 day [P3] <input type="checkbox"/>		2 day [P2] <input type="checkbox"/>		1 Business day [E1] <input type="checkbox"/>		Same Day, Weekend or Statutory holiday [E0] <input type="checkbox"/>				
Phone: (807) 275-6762		<input type="checkbox"/> Compare Results to Criteria on Report - provide details below if box checked			Date and Time Required for all E&P TATs:												
Street: 522 2ND ST. EAST		Email 1 or Fax peter.gardiman@mail.rdsb.com			For tests that can not be performed according to the service level selected, you will be contacted.												
City/Province: Fort Frances, ON		Email 2 sherri.belluz@mail.rdsb.com			Analysis Request												
Postal Code: P9A 1N4		Email 3			Indicate Filtered (F), Preserved (P) or Filtered and Preserved (F/P) below												
Invoice To		Invoice Distribution			Number of Containers												
Same as Report To <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		Select Invoice Distribution: <input checked="" type="checkbox"/> EMAIL <input type="checkbox"/> MAIL <input type="checkbox"/> FAX															
Copy of Invoice with Report <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		Company: Rainy River District School Board															
Company: Rainy River District School Board		Email 1 or Fax peter.gardiman@mail.rdsb.com															
Contact: Peter Gardiman		Email 2 sherri.belluz@mail.rdsb.com															
Project Information		Oil and Gas Required Fields (client use)															
ALS Account # / Quote #:		AFE/Cost Center:		PO#													
Job #: RRDSB - Nestor Falls School		Major/Minor Code:		Routing Code:													
PO / AFE:		Requisitioner:															
LSD:		Location:															
ALS Lab Work Order # (lab use only) L1997349		ALS Contact:		Sampler:													
ALS Sample # (lab use only)	Sample Identification and/or Coordinates (This description will appear on the report)	Date (dd-mmm-yy)	Time (hh:mm)	Sample Type	Hardness* (Ca/Mg, Mn/Fe)	Sodium	Total Coliform, E.coli, HPC *	Chloride, Colour, pH *	TSS *	UV Transmittance *	Nitrogen Cycle (NO2, NO3, NH3, TKN, Organic Nitrogen), Chloride, Colour, pH						
	Raw MECH. ROOM	25-9-17	11:45AM	Water	R	R	R	R	R	R							
	Treated MECH. ROOM	25-9-17	11:45AM	Water	R		R	R	R	R							
Drinking Water (DW) Samples <sup>1</sup> (client use)		Special Instructions / Specify Criteria to add on report by clicking on the drop-down list below (electronic COC only)			SAMPLE CONDITION AS RECEIVED (lab use only)												
Are samples taken from a Regulated DW System? <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO					Frozen <input type="checkbox"/> SIF Observations Yes <input type="checkbox"/> No <input type="checkbox"/>												
Are samples for human drinking water use? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO					Ice Packs <input checked="" type="checkbox"/> Ice Cubes <input type="checkbox"/> Custody seal intact Yes <input type="checkbox"/> No <input type="checkbox"/>												
					Cooling initiated <input checked="" type="checkbox"/>												
					INITIAL COOLER TEMPERATURES °C					FINAL COOLER TEMPERATURES °C							
					4.4												
SHIPMENT RELEASE (client use)				INITIAL SHIPMENT RECEPTION (lab use only)				FINAL SHIPMENT RECEPTION (lab use only)									
Released by: Charles Deschamps		Date: Sept 25/17		Time: 11:45AM		Received by: JRCe		Date: Sept 26		Time: 13:40		Received by:		Date:		Time:	