




Rainy River District School Board
ATTN: Travis Enge
RE: MINE CENTRE
522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Date Received: 01-FEB-18
Report Date: 02-FEB-18 14:47 (MT)
Version: FINAL

Client Phone: 807-275-6762

Certificate of Analysis

Lab Work Order #: L2051855
Project P.O. #: MINE CENTRE
Job Reference: 260015002
C of C Numbers:
Legal Site Desc:



Christina Shepherd
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1081 Barton Street, Thunder Bay, ON P7B 5N3 Canada | Phone: +1 807 623 6463 | Fax: +1 807 623 7598
ALS CANADA LTD Part of the ALS Group An ALS Limited Company



ANALYTICAL GUIDELINE REPORT

260015002

Sample Details		Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits							
Grouping	Analyte						#1	#2						
L2051855-1 ~R1 1 MECHANICAL RM RAW														
Sampled By: CG on 31-JAN-18 @ 07:15														
Matrix: RAW WATER														
Bacteriological Tests														
Escherichia Coli		0		0	MPN/100m L	01-FEB-18	0							
Total Coliforms		0		0	MPN/100m L	01-FEB-18	0							

** Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

Ontario Drinking Water Regulation (ODWQS) JAN.1,2017 = [Suite] - ON-DW-STANDARD+GUIDELINES

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2017)

#2: Ontario DW Aesthetic and Operational Guidelines

Reference Information

Qualifiers for Individual Samples Listed:

Sample Number	Client ID	Qualifier	Description
L2051855-2	-D1 2 KINDERGARTEN RM	NDSF	No Data: Sample Received Frozen.

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference***
TC,EC-QT97-TB	Water	Total Coliform and E.coli	APHA 9223 B

This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.

*** ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
TB	ALS ENVIRONMENTAL - THUNDER BAY, ONTARIO, CANADA		

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information.



Environmental

Quality Control Report

Workorder: L2051855

Report Date: 02-FEB-18

Page 1 of 2

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Contact: Travis Enge

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
TC,EC-QT97-TB								
	Water							
Batch	R3951352							
WG2709338-2	DUP	L2051855-1						
Total Coliforms		0	0		MPN/100mL	0.0	65	01-FEB-18
Escherichia Coli		0	0		MPN/100mL	0.0	65	01-FEB-18
WG2709338-1	MB							
Total Coliforms			0		MPN/100mL		1	01-FEB-18
Escherichia Coli			0		MPN/100mL		1	01-FEB-18

Quality Control Report

Workorder: L2051855

Report Date: 02-FEB-18

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Page 2 of 2

Contact: Travis Enge

Legend:

Limit	ALS Control Limit (Data Quality Objectives)
DUP	Duplicate
RPD	Relative Percent Difference
N/A	Not Available
LCS	Laboratory Control Sample
SRM	Standard Reference Material
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ADE	Average Desorption Efficiency
MB	Method Blank
IRM	Internal Reference Material
CRM	Certified Reference Material
CCV	Continuing Calibration Verification
CVS	Calibration Verification Standard
LCSD	Laboratory Control Sample Duplicate

Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



L2051855-COFC
L2051864-COFC

128


DRINKING WATER CHAIN OF CUSTODY

PLEASE CIRCLE APPLICABLE REGULATION:

Reg 170/03 Reg 318/08 319/08 Reg 243 C of A

Is this a resample from an adverse water quality incident? Yes No

NYI



WORKS NAME RRDSS - Mine Centre School		WORKS PHONE School: 807-599-2843 Site: 807-275-4979		ANALYSIS REQUIRED		DATE 02/01/18		SUBMITTER TO LAB LS		TEMPERATURE AT RECEIPT 0.2	
CLIENT CONTACT NAME Travis Engle		WORKS FAX School: 807-599-9911 Admin: 807-274-5078		Please indicate test for each sample by checkmark in the box below		TIME 15:40		VOLUME 1L		TIME CHECK	
WORKS ADDRESS (physical) 123 Mine Centre Road, Mine Centre, ON, P0W 1H0		ALTER HOURS PHONE Peter: 807-275-6762 Travis: 807-276-4733		HEALTH UNIT NWDIU		HEALTH UNIT NWDIU		Regulated Sample Type (R, T, D, P, PS, PF)		Field pH	
REPORTING ADDRESS 522 Second St. E., Fort Frances, ON, P9A 1N4		HEALTH UNIT Kenora: 807-468-3147/807-468-3914 Phone/Fax: Fort Frances: 807-274-9827/807-274-0719		Requested Service (Circle One) Reg		Sample Date Jan 31/18		Sample Time 7:25 AM		Total Coliform/E. coli (TC/EC)	
EMAIL: sherril@huzemrnl.trish.com peter.gardiner@mail.rrdss.com		Requested Service (Circle One) Energy (008)		Sample Date Jan 31/18		Sample Time 7:25 AM		Regulated Sample Type (R, T, D, P, PS, PF)		Het. Plate Count (HPC)	
SAMPLE DESCRIPTION (This description will appear on the report)		Chlorine Residual mg/L		Sample Date		Sample Time		Regulated Sample Type (R, T, D, P, PS, PF)		Nitrate/Nitrite	
#1 Mechanical Am Raw		N/A		Jan 31/18		7:25 AM		R		THM (Max. Res. Time)	
#2 Kindergarten Am. Dist		N/A		Jan 31/18		7:25 AM		D		Sched 23 Inorganics	
#3 Mechanical Am. Valve #26		N/A		Jan 31/18		7:25 AM		T		Sched 24 Organics	
TREATED SOURCE										Sodium	
										Fluoride	
										Turbidity	
										Lead	
										Alkalinity	
										Other:	
										Field pH	
										pH < 2	
										Volume	
										Time	
										CHECK TO LIST ON REPORT	
SAMPLED BY (PRINT) C. Gustafson		SIGNED BY (SIGNATURE) <i>C. Gustafson</i>		DATE/TIME RECEIVED 02/01/18		DATE/TIME RECEIVED LS		RECEIVED BY (PRINT) LS		CHECK TO LIST ON REPORT	
SUBMITTED TO LAB BY (PRINT) C. Gustafson		SIGNED BY (SIGNATURE) <i>C. Gustafson</i>		DATE/TIME RECEIVED 02/01/18		DATE/TIME RECEIVED LS		RECEIVED BY (PRINT) LS		CHECK TO LIST ON REPORT	

LS




Rainy River District School Board
ATTN: Travis Enge
RE: MINE CENTRE
522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Date Received: 19-JAN-18
Report Date: 23-JAN-18 14:10 (MT)
Version: FINAL

Client Phone: 807-275-6762

Certificate of Analysis

Lab Work Order #: L2047151
Project P.O. #: MINE CENTRE
Job Reference: 260015002
C of C Numbers:
Legal Site Desc:



Christina Shepherd
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1081 Barton Street, Thunder Bay, ON P7B 5N3 Canada | Phone: +1 807 623 6463 | Fax: +1 807 623 7598
ALS CANADA LTD Part of the ALS Group An ALS Limited Company



ANALYTICAL GUIDELINE REPORT

260015002

Sample Details		Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits							
Grouping	Analyte						#1	#2						
L2047151-2 -D1 1 KINDERGARTEN RM DIST														
Sampled By: CG on 18-JAN-18 @ 07:25														
Matrix: DISTRIBUTION														
Bacteriological Tests														
Escherichia Coli		0		0	MPN/100m L	19-JAN-18	0							
Heterotrophic Plate Count		0		0	CFU/mL	19-JAN-18								
Total Coliforms		0		0	MPN/100m L	19-JAN-18	0							

** Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

Ontario Drinking Water Regulation (ODWQS) JAN.1,2017 = [Suite] - ON-DW-STANDARD+GUIDELINES

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2017)

#2: Ontario DW Aesthetic and Operational Guidelines

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference***
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215B (modified)
		Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.	
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215D (modified)
		Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.	
TC,EC-QT51-TB	Water	Total Coliform and E.coli	APHA 9223 B

This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.

*** ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
TB	ALS ENVIRONMENTAL - THUNDER BAY, ONTARIO, CANADA		

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information.



Quality Control Report

Workorder: L2047151

Report Date: 23-JAN-18

Page 1 of 2

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Contact: Travis Enge

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
HPC-PP-TB								
	Water							
Batch	R3940296							
WG2701768-2	DUP	L2047151-2						
Heterotrophic Plate Count		0	0		CFU/mL	0.0	65	19-JAN-18
WG2701768-1	MB							
Heterotrophic Plate Count			0		CFU/mL		1	19-JAN-18
TC,EC-QT51-TB								
	Water							
Batch	R3939977							
WG2701573-1	MB							
Total Coliforms			0		MPN/100mL		1	19-JAN-18
Escherichia Coli			0		MPN/100mL		1	19-JAN-18

Quality Control Report

Workorder: L2047151

Report Date: 23-JAN-18

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Page 2 of 2

Contact: Travis Enge

Legend:

Limit	ALS Control Limit (Data Quality Objectives)
DUP	Duplicate
RPD	Relative Percent Difference
N/A	Not Available
LCS	Laboratory Control Sample
SRM	Standard Reference Material
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ADE	Average Desorption Efficiency
MB	Method Blank
IRM	Internal Reference Material
CRM	Certified Reference Material
CCV	Continuing Calibration Verification
CVS	Calibration Verification Standard
LCSD	Laboratory Control Sample Duplicate

Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.


ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



L2047151-COFC



DRINKING WATER CHAIN OF CUSTODY

PLEASE CIRCLE APPLICABLE REGULATION:

Reg 170/03

Reg 318/08 319/08

Reg 243

C of A

ALS Thunder Bay, 1081 Barton Street, Thunder Bay, ON P7R 5N3
Ph: 807-623-6463 Fax: 807-623-7598 Toll-Free: 1-800-668-9878

Is this a resample from an adverse water quality incident? Yes No

WORKS NAME RRDSB - Mine Centre School		WORKS PHONE School: 807-599-2843 Sheri: 807-275-4979		ANALYSIS REQUESTED Please indicate test for each sample by Checkmark in the box below										FOR LAB USE ONLY					
CLIENT CONTACT NAME Travis Enge		WORKS FAX School: 807-599-9911 Admin: 807-274-5078		Total Coliform/E. coli (TC/EC)	Het. Plate Count (HPC)	Nitrate/Nitrite	THM (Max. Res. Time)	Sched 23 Inorganics	Sched 24 Organics	Sodium	Fluoride	Turbidity	Lead	Alkalinity	Other:	Field pH	SUBMISSION NO. L2047151		
WORKS ADDRESS (physical) 123 Mine Centre Road, Mine Centre, ON, P0W 1H0		AFTER HOURS PHONE Peter: 807-275-6762 Travis: 807-276-4733															LOGGED BY JTR		
REPORTING ADDRESS 522 Second St. E., Fort Frances, ON, P9A 1N4		HEALTH UNIT NWDHU															DATE Jan 19/18		
WORKS/DWIS/SDWS NUMBER 260015002		HEALTH UNIT Kenora: 807-468-3147/807-468-3914 PHONE/FAX Fort Frances: 807-274-9827/807-274-0779		Requested Service (Circle One) Reg <input checked="" type="checkbox"/> Pri (50%) <input type="checkbox"/> Emery (100%) <input type="checkbox"/>			TIME 13:58			TEMPERATURE AT RECEIPT (C) 8-1									
EMAIL: sherri.belluzzi@mail.rrdsb.com peter.gardiman@mail.rrdsb.com		Chlorine Residual mg/L	Sample Date	Sample Time	Regulated Sample Type * (R, T, D, P, PS, PF)	pH	e2	Volume L	Time Check	SAMPLE DESCRIPTION (This description will appear on the report)									
#1 Kindergarten Am. Dist.										M/A JAN 18/18 7:25AM D X X									
SAMPLED BY (PRINT) C. Gustafson		SAMPLED BY (SIGNATURE) <i>C. Gustafson</i>		DATE/TIME RECEIVED AT LAB: Jan 19/18 13:49		OTHER COMMENTS/CAUTIONS (Please identify known or suspected hazards)										CHECK TO LIST ON REPORT			
SUBMITTED TO LAB BY (PRINT) C. Gustafson		SUBMITTED TO LAB BY (SIGNATURE) <i>C. Gustafson</i>		RECEIVED AT LAB BY: JTR												Chlorine Residual(s)			
																Field pH(s)			



Rainy River District School Board
ATTN: Travis Enge
RE: MINE CENTRE
522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Date Received: 03-JAN-18
Report Date: 08-JAN-18 09:54 (MT)
Version: FINAL

Client Phone: 807-275-6762

Certificate of Analysis

Lab Work Order #: L2040865
Project P.O. #: MINE CENTRE
Job Reference: 260015002
C of C Numbers:
Legal Site Desc:

Christina Shepherd
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1081 Barton Street, Thunder Bay, ON P7B 5N3 Canada | Phone: +1 807 623 6463 | Fax: +1 807 623 7598
ALS CANADA LTD Part of the ALS Group An ALS Limited Company



ANALYTICAL GUIDELINE REPORT

260015002

Sample Details		Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits							
Grouping	Analyte						#1	#2						
L2040865-1	-R1 1 MECHANICAL RM RAW													
Sampled By: C GUSTAFSON on 02-JAN-18 @ 1														
Matrix: RAW WATER														
Bacteriological Tests														
Escherichia Coli		0		0	MPN/100m L	03-JAN-18	0							
Total Coliforms		0		0	MPN/100m L	03-JAN-18	0							
L2040865-2	-D1 2 KINDERGARTEN RM DIST													
Sampled By: C GUSTAFSON on 02-JAN-18 @ 1														
Matrix: DISTRIBUTION														
Bacteriological Tests														
Escherichia Coli		0		0	MPN/100m L	03-JAN-18	0							
Heterotrophic Plate Count		1		0	CFU/mL	03-JAN-18								
Total Coliforms		0		0	MPN/100m L	03-JAN-18	0							

** Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

Ontario Drinking Water Regulation (ODWQS) JAN.1,2017 = [Suite] - ON-DW-STANDARD+GUIDELINES

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2017)

#2: Ontario DW Aesthetic and Operational Guidelines

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference***
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215B (modified)
		Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.	
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215D (modified)
		Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.	
TC,EC-QT51-TB	Water	Total Coliform and E.coli	APHA 9223 B

This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.

TC,EC-QT97-TB	Water	Total Coliform and E.coli	APHA 9223 B
---------------	-------	---------------------------	-------------

This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.

*** ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
TB	ALS ENVIRONMENTAL - THUNDER BAY, ONTARIO, CANADA		

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information.



Quality Control Report

Workorder: L2040865

Report Date: 08-JAN-18

Page 1 of 2

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Contact: Travis Enge

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
HPC-PP-TB								
	Water							
Batch	R3929373							
WG2693277-2	DUP	L2040865-2						
Heterotrophic Plate Count		1	0	J	CFU/mL	1	2	03-JAN-18
WG2693277-1	MB							
Heterotrophic Plate Count			0		CFU/mL		1	03-JAN-18
TC,EC-QT51-TB								
	Water							
Batch	R3928534							
WG2693319-1	MB							
Total Coliforms			0		MPN/100mL		1	03-JAN-18
Escherichia Coli			0		MPN/100mL		1	03-JAN-18
TC,EC-QT97-TB								
	Water							
Batch	R3928461							
WG2693243-2	DUP	L2040950-1						
Total Coliforms		0	2	DUPM	MPN/100mL	2	2	03-JAN-18
Escherichia Coli		0	0		MPN/100mL	0.0	65	03-JAN-18
WG2693243-1	MB							
Total Coliforms			0		MPN/100mL		1	03-JAN-18
Escherichia Coli			0		MPN/100mL		1	03-JAN-18

Quality Control Report

Workorder: L2040865

Report Date: 08-JAN-18

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Page 2 of 2

Contact: Travis Enge

Legend:

Limit ALS Control Limit (Data Quality Objectives)
DUP Duplicate
RPD Relative Percent Difference
N/A Not Available
LCS Laboratory Control Sample
SRM Standard Reference Material
MS Matrix Spike
MSD Matrix Spike Duplicate
ADE Average Desorption Efficiency
MB Method Blank
IRM Internal Reference Material
CRM Certified Reference Material
CCV Continuing Calibration Verification
CVS Calibration Verification Standard
LCSD Laboratory Control Sample Duplicate

Sample Parameter Qualifier Definitions:

Qualifier	Description
DUPM	MPN duplicate results were outside default ALS Data Quality Objective, but within 95% confidence interval for MPN reference method. Sample results are reliable.
J	Duplicate results and limits are expressed in terms of absolute difference.

Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



L2040865-COFC

ALS Thunder Bay, 1081 Barton Street, Thunder Bay, ON P7B 5N3
Ph. 807-623-6463 Fax: 807-623-7598 Toll-Free 1-800-668-9878

DRINKING WATER CHAIN OF CUSTODY

PLEASE CIRCLE APPLICABLE REGULATION:

Reg 170/03

Reg 318/08 319/08

Reg 243

C of A

Is this a resample from an adverse water quality incident? Yes No

WORKS NAME		WORKS PHONE		ANALYSES REQUESTED												FOR LAB USE ONLY					
RR05B - Mine Centre School		School: 807-599-2843 Sherri: 807-275-4979		Please indicate test for each sample by Checkmark in the box below												SUBMISSION NO. L2040865					
CLIENT CONTACT NAME		WORKS FAX		Total Coliform/E. coli (TC/EC)	Het. Plate Count (HPC)	Nitrate/Nitrite	THM (Max. Res. Time)	Sched 23 Inorganics	Sched 24 Organics	Sodium	Fluoride	Turbidity	Lead	Alkalinity	Other	Field pH	LOGGED BY JTR				
Travis Enge		School: 807-599-9911 Admin: 807-274-5078															DATE 01/10/18				
WORKS ADDRESS(physical)		AFTER HOURS PHONE		HEALTH UNIT			TIME			TEMPERATURE AT RECEIPT (C)			pH <2			Volume LL			Time Check		
123 Mine Centre Road, Mine Centre, ON, P0W 1H0		Peter: 807-275-6762 Travis: 807-276-4733		NWDHU			1:56			5.0											
REPORTING ADDRESS		HEALTH UNIT		HEALTH UNIT			Regulated Sample Type * (R,T,D,P,RS,PF)														
522 Second St. E., Fort Frances, ON, P9A 1N4		NWDHU		Keno: 807-468-3147/807-468-3914																	
WORKS/DWIS/SOWS NUMBER		PHONE/FAX		Requested Service (Circle One)																	
260015002		Fort Frances: 807-274-9827/807-274-0779		Reg (Req) Pri (50%) Emerg (100%)																	
E-MAIL: sheri.helluz@mail.rrdsb.com peter.gardiman@mail.rrdsb.com																					
SAMPLE DESCRIPTION (This description will appear on the report)		Chlorine Residual mg/L	Sample Date	Sample Time																	
#1 mechanical/Rm. RAW		N/A	JAN 2/18	10:15AM	R. X																
#2 Kindergarten Rm. Dist		N/A	JAN 2/18	10:20AM	D. X X																

* Sample Type Legend: R - Raw Water T - Treated Source D - Distribution Sample P - Plumbing PS - Plumbing Standing PF - Plumbing Flushed

SAMPLED BY (PRINT)		SAMPLED BY (SIGNATURE)		DATE/TIME RECEIVED AT LAB		Enter Comments/Cautions (Please identify known or suspected hazards)						CHECK TO LIST ON REPORT		
C. Gustafson		<i>C. Gustafson</i>		3 Jan 18 1335								Chlorine Residual(s)		
SUBMITTED TO LAB BY (PRINT)		SUBMITTED TO LAB BY (SIGNATURE)		RECEIVED AT LAB BY:								Field pH(s)		
C. Gustafson		<i>C. Gustafson</i>		MM										

JTR