




Rainy River District School Board
ATTN: Travis Enge
RE: MINE CENTRE
522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Date Received: 06-APR-18
Report Date: 09-APR-18 12:52 (MT)
Version: FINAL

Client Phone: 807-275-6762

Certificate of Analysis

Lab Work Order #: L2076851
Project P.O. #: MINE CENTRE
Job Reference: 260015002
C of C Numbers:
Legal Site Desc:



Christina Shepherd
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 1081 Barton Street, Thunder Bay, ON P7B 5N3 Canada | Phone: +1 807 623 6463 | Fax: +1 807 623 7598
ALS CANADA LTD Part of the ALS Group An ALS Limited Company



ANALYTICAL GUIDELINE REPORT

260015002

Sample Details		Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits					
Grouping	Analyte						#1	#2				
L2076851-1 ~R1 1 MECHANICAL RM RAW Sampled By: CG on 05-APR-18 @ 07:15 Matrix: RAW WATER							#1	#2				
Bacteriological Tests												
Escherichia Coli		0		0	MPN/100m L	06-APR-18	0					
Total Coliforms		0		0	MPN/100m L	06-APR-18	0					
L2076851-2 ~D1 2 KINDERGARTEN RM DIST. Sampled By: CG on 05-APR-18 @ 07:22 Matrix: DISTRIBUTION							#1	#2				
Bacteriological Tests												
Escherichia Coli		0		0	MPN/100m L	06-APR-18	0					
Heterotrophic Plate Count		3		0	CFU/mL	06-APR-18						
Total Coliforms		0		0	MPN/100m L	06-APR-18	0					

** Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

Ontario Drinking Water Regulation (ODWQS) JAN.1,2018 = [Suite] - ON-DW-STANDARD+GUIDELINES

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2018)

#2: Ontario DW Aesthetic and Operational Guidelines

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference***
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215B (modified)
Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.			
HPC-PP-TB	Water	Heterotrophic Plate Count by Pour Plate	APHA 9215D (modified)
Heterotrophic Plate Count in aqueous matrices are analyzed using aerobic incubation and pour plate method and incubated for 48 hours.			
TC,EC-QT51-TB	Water	Total Coliform and E.coli	APHA 9223 B

This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.

TC,EC-QT97-TB	Water	Total Coliform and E.coli	APHA 9223 B
---------------	-------	---------------------------	-------------

This analysis is carried out using procedures adapted from APHA Method 9223 "Enzyme Substrate Coliform Test". E. coli and Total Coliform are determined simultaneously. The sample is mixed with a mixture of hydrolyzable substrates and then sealed in a multi-well packet. The packet is incubated for 18 or 24 hours and then the number of wells exhibiting a positive response are counted. The final result is obtained by comparing the positive responses to a probability table.

*** ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
TB	ALS ENVIRONMENTAL - THUNDER BAY, ONTARIO, CANADA		

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information.



Quality Control Report

Workorder: L2076851

Report Date: 09-APR-18

Page 1 of 2

Client: Rainy River District School Board
 RE: MINE CENTRE 522 2ND ST EAST
 FORT FRANCES ON P9A 1N4

Contact: Travis Enge

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
HPC-PP-TB								
	Water							
Batch	R4006649							
WG2746642-2	DUP	L2076846-4						
Heterotrophic Plate Count		0	0		CFU/mL	0.0	65	06-APR-18
WG2746642-1	MB							
Heterotrophic Plate Count			0		CFU/mL		1	06-APR-18
TC,EC-QT51-TB								
	Water							
Batch	R4006322							
WG2746501-1	MB							
Total Coliforms			0		MPN/100mL		1	06-APR-18
Escherichia Coli			0		MPN/100mL		1	06-APR-18
TC,EC-QT97-TB								
	Water							
Batch	R4006386							
WG2746691-2	DUP	L2076870-1						
Total Coliforms		0	0		MPN/100mL	0.0	65	06-APR-18
Escherichia Coli		0	0		MPN/100mL	0.0	65	06-APR-18
WG2746691-1	MB							
Total Coliforms			0		MPN/100mL		1	06-APR-18
Escherichia Coli			0		MPN/100mL		1	06-APR-18

Quality Control Report

Workorder: L2076851

Report Date: 09-APR-18

Client: Rainy River District School Board
RE: MINE CENTRE 522 2ND ST EAST
FORT FRANCES ON P9A 1N4

Page 2 of 2

Contact: Travis Enge

Legend:

Limit	ALS Control Limit (Data Quality Objectives)
DUP	Duplicate
RPD	Relative Percent Difference
N/A	Not Available
LCS	Laboratory Control Sample
SRM	Standard Reference Material
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ADE	Average Desorption Efficiency
MB	Method Blank
IRM	Internal Reference Material
CRM	Certified Reference Material
CCV	Continuing Calibration Verification
CVS	Calibration Verification Standard
LCSD	Laboratory Control Sample Duplicate

Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.



L2076851-COFC

DRINKING WATER CHAIN OF CUSTODY

PLEASE CIRCLE APPLICABLE REGULATION:

Reg 170/03

Reg 318/08 319/08

Reg 243

C of A

Is this a re-sample from an adverse water quality incident? Yes No

ALS Thunder Bay, 1081 Barton Street, Thunder Bay, ON P7B 5N3
Ph: 807-623-6463 Fax: 807-623-7598 Toll-Free 1-800-668-9878

WORKS NAME RRDSB - Mine Centre School		WORKS PHONE School: 807-599-2843 Sheriff: 807-275-4979		ANALYSIS REQUESTED Please indicate test for each sample by Checkmark in the box below										FOR LAB USE ONLY					
CLIENT CONTACT NAME Travis Enge		WORKS FAX School: 807-599-9011 Admin: 807-274-5078		Total Coliform/E. coli (TC/EC)	Het. Plate Count (HPC)	Nitrate/Nitrite	THM (Max. Res. Time)	Sched 23 Inorganics	Sched 24 Organics	Sodium	Fluoride	Turbidity	Lead	Alkalinity	Other:	Field pH	SUBMISSION NO. L2076851		
WORKS ADDRESS (physical) 123 Mine Centre Road, Mine Centre, ON, P0W 1H0		AFTER HOURS PHONE Peter: 807-275-6762 Travis: 807-276-4733															LOGGED BY KW		
REPORTING ADDRESS 522 Second St. E., Fort Frances, ON, P9A 1N4		HEALTH UNIT NWDHU															DATE Apr. 6/18		
WORKS/DWIS/SOWS NUMBER 260015002		HEALTH UNIT - Area: 807-468-3147/807-468-3914 PHONE/FAX Fort Frances: 807-274-9827/807-274-0779															TIME 1:50		
EMAIL: sheri.belluz@mail.rrdsh.com peter.gardman@mail.rrdsh.com		Requested Service (Circle One) <input checked="" type="radio"/> Raw (50%) <input type="radio"/> Plumb (100%) <input type="radio"/> Emergency (100%)		Regulated Sample Type (R, T, D, P, PS, PF)											TEMPERATURE AT RECEIPT (C) 7.4°				
SAMPLE DESCRIPTION (This description will appear on the report)		Chlorine Residual mg/l	Sample Date		Sample Time											pH	Volume l	Time Check	
#1 Mechanical Rm Raw		N/A	April 5/18	7:15AM	R	X													
#2 Kindergarten Rm. Dist		N/A	April 5/18	7:22AM	D	X	X												
SAMPLED BY (PRINT) C. Gustafson		SAMPLED BY (SIGNATURE) <i>C. Gustafson</i>		DATE/TIME RECEIVED AT LAB 04-06-2018 1:15pm		OTHER COMMENTS/Concerns (Please identify known or suspected hazards) Collect - courtesy - 5541014286										CHECK TO LIST ON REPORT Chlorine Residuals) <input type="checkbox"/> pH) <input type="checkbox"/>			
SUBMITTED TO LAB BY (PRINT) C. Gustafson		SUBMITTED TO LAB BY (SIGNATURE) <i>C. Gustafson</i>		RECEIVED AT LAB BY <i>[Signature]</i>															