











# Rainy River District School Board

McCrosson-Tovell School - SFIS #9382 - Plumbing Installed 1968

Water Flushing Procedure and Record Sheet - DWS 260009789 / 500124814

Flushing Procedure: Any errors or omissions must be reported to the Manager of Plant Operations and Maintenance immediately. Do not modify this form without approval.

- THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM, WEEKLY FLUSHING MUST BE DONE ON MONDAYS.
- Refer to the McCrosson-Tovell School Flushing Floor Plan for the location of the sinks listed below.
  - 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
  - 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was started only.

Year	Month	Flushing Type: Weekly	10 Second Flush - Record Time Completed in Space																	Flushing Completed By Name
			Rm17 Girls Washroom Start	Rm17 Girls Washroom End	Rm16 Boys 1 Sink	Rm15 Lunch 3 Sinks	Rm14 Library 1 Sink	Rm13 Comp 1 Sinks	Rm12 Speech 1 Sink	Rm11 Staff 1 Sink	Rm10 Wash 1 Sink	North Fountain	Rm8 Class 1 Sink	Rm7 Resource 1 Sink	Rm6 Boys 2 Sinks	Rm5 Girls 2 Sinks	Rm2 Stock 2 Sinks	Rm3 Class 1 Sink	South Fountain	
2016	June	1	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	7	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	13	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	20	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	21	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	22	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	23	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	24	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	25	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	26	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	27	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	28	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	29	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	30	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David
2016	June	31	7:30	7:35	7:36	7:38	7:39	7:40	7:41	7:42	7:43	7:37	7:44	7:45	7:46	7:48	7:50	7:49	7:47	Murray, David

OS=sink/fountain is out of service and cannot be flushed

