

2
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 50011606

Rev 05-21-15

Flushing Procedure. Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 6:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily											Flushing
Month	10 Second Flush - Record Time Completed in Space											Completed By
Day	NW Hall (Guidance) Fountains	Room 19 (Guidance)		Main Entrance Washrooms		Room 4	Principal	Main Kitchen	Main Office	First Nation Counsel	Fountain	Name
		Main Room	Office bath	Boys	Girls							
1	0:5	8:03	8:02	8:04	8:05	8:06	8:07	8:08	8:09	8:10	8:11	[Signature]
2	0:5	8:04	8:03	8:05	8:06	8:07	8:08	8:10	8:11	8:15		
3	:	:	:	:	:	:	:	:	:	:	:	
4	:	:	:	:	:	:	:	:	:	:	:	
5	0:5	8:02	8:02	7:55	7:56	7:56	7:57	7:57	7:58	7:59	8:00	Allen [Signature]
6	0:5	7:50	7:50	7:41	7:41	7:42	7:43	7:44	7:48	7:46	7:48	Allen [Signature]
7	0:5	7:54	7:54	7:55	7:46	7:46	7:47	7:48	7:49	7:52	7:52	Allen [Signature]
8	0:5	7:57	7:57	7:48	7:48	7:49	7:50	7:51	7:52	7:53	7:54	Allen [Signature]
9	0:5	7:43	7:43	7:33	7:34	7:35	7:36	7:38	7:37	7:38	7:40	Allen [Signature]
10	:	:	:	:	:	:	:	:	:	:	:	
11	:	:	:	:	:	:	:	:	:	:	:	
12	:	:	:	:	:	:	:	:	:	:	:	
13	:	:	:	:	:	:	:	:	:	:	:	
14	:	:	:	:	:	:	:	:	:	:	:	
15	:	:	:	:	:	:	:	:	:	:	:	
16	:	:	:	:	:	:	:	:	:	:	:	
17	:	:	:	:	:	:	:	:	:	:	:	
18	:	:	:	:	:	:	:	:	:	:	:	
19	0:5	8:03	8:03	8:04	8:05	8:06	8:07	8:08	8:09	8:11	8:11	Christ [Signature]
20	0:5	8:04	8:03	8:05	8:05	8:06	8:07	8:08	8:09	8:10	8:11	Christ [Signature]
21	0:5	7:53	7:53	7:54	7:55	7:56	7:58	8:00	8:01	8:02	8:03	Christ [Signature]
22	0:5	7:58	7:58	8:00	8:01	8:02	8:03	8:05	8:05	8:08	8:09	Christ [Signature]
23	0:5	8:09	8:10	8:11	8:11	8:12	8:14	8:14	8:15	8:16	8:17	Christ [Signature]
24	:	:	:	:	:	:	:	:	:	:	:	
25	:	:	:	:	:	:	:	:	:	:	:	
26	8:00	8:01	8:01	7:51	7:52	7:53	7:53	7:54	7:55	7:56	7:57	Allen [Signature]
27	7:42	7:43	7:43	7:35	7:36	7:37	7:37	7:38	7:38	7:39	7:40	Allen [Signature]
28	7:48	7:49	7:49	7:39	7:40	7:41	7:42	7:44	7:43	7:45	7:46	Allen [Signature]
29	7:54	7:54	7:55	7:43	7:44	7:45	7:46	7:47	7:48	7:49	7:50	Allen [Signature]
30	:	:	:	:	:	:	:	:	:	:	:	
31	:	:	:	:	:	:	:	:	:	:	:	

OS = Out of Service

1
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 500111606

Rev 05/21/15

Flushing Procedure: Any errors or omissions must be reported to the Manager of Plant Operations and Misc immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM WEEKLY FLUSHING MUST BE DONE ON MONDAYS

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sink's cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily																Principal				
2018	**All times AM and recorded to the nearest minute. Ex: 7:46**																				
Feb	5 Minute Flush																10 Second Flush - Record Time Completed in Space				Flushing
Day	Girl's Changeroom (both sinks)		Boy's Washroom By Gym		Room 10 (west sink)		Rm 10 East	Rm 8	Rm 7 & Winkroom	Accessible WR	Girls Gym Entry Washroom	Gym Entrance	Boy's Changeroom	Staffroom	Rm 12	Room 13	Library Workroom	Completed By			
	Start	End	Start	End	Start	End	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	Fountain	1 Sink	3 Sinks	2 Sinks	1 Sink	1 Sink	Name			
1	7:06	7:10	7:09	7:14	7:04	7:11	7:04	7:05	7:06	7:07	7:08	7:09	7:30	7:51	7:53	7:54	7:55	Alton			
2	7:13	7:16	7:12	7:17	7:11	7:18	7:08	7:30	7:50	7:51	7:52	7:53	7:54	7:56	7:57	7:58	7:59	Alton			
3																					
4																					
5	7:07	7:48	7:09	7:50	7:03	7:51	7:52	7:53	7:55	8:04	7:50	7:49	7:49	8:09	8:10	8:11	8:09	Alton			
6	7:04	7:37	7:06	7:39	7:00	7:40	7:41	7:42	7:45	7:55	7:39	7:38	7:37	7:59	8:00	8:01	7:59	Alton			
7	7:03	7:32	7:05	7:36	7:00	7:37	7:38	7:39	7:40	7:50	7:36	7:35	7:34	7:54	7:55	7:56	7:53	Alton			
8	7:05	7:38	7:07	7:40	7:01	7:41	7:42	7:43	7:44	7:54	7:40	7:39	7:38	7:59	8:00	8:01	7:58	Alton			
9	7:10	7:41	7:12	7:43	7:03	7:44	7:45	7:46	7:48	8:00	7:43	7:42	7:41	8:04	8:05	8:06	8:04	Alton			
10																					
11																					
12	7:06	8:00	7:04	8:06	7:03	8:06	8:07	8:08	8:09	0:5	8:01	8:12	8:13	8:14	8:15	8:16	8:17	Alton			
13	7:16	7:23	7:15	7:23	7:15	7:25	7:25	7:27	7:27	0:5	7:29	7:29	7:30	7:31	7:32	7:32	7:36	Alton			
14	7:12	7:39	7:10	7:40	7:10	7:42	7:43	7:43	7:45	7:45	7:47	7:48	7:49	7:50	7:51	7:53	7:55	Alton			
15	7:11	7:36	7:09	7:37	7:09	7:38	7:38	7:39	7:40	7:40	7:41	7:42	7:43	7:47	7:49	7:50	7:52	Alton			
16	7:02	7:05	7:00	7:46	6:59	7:46	7:49	7:50	7:52	7:52	7:53	7:54	7:56	7:57	7:58	7:59	8:00	Alton			
17																					
18																					
19																					
20	7:10	7:49	7:12	7:51	7:04	7:52	7:53	7:55	7:56	8:06	7:51	7:50	7:49	8:11	8:12	8:13	8:10	Alton			
21	7:06	7:53	7:08	7:55	7:01	7:56	7:56	7:57	7:59	8:07	7:55	7:55	7:54	8:11	8:12	8:13	8:10	Alton			
22	7:03	7:22	7:05	7:25	7:00	7:26	7:26	7:27	7:28	2:36	7:25	7:24	7:23	7:39	7:40	7:41	7:38	Alton			
23	7:03	7:47	7:05	7:49	6:58	7:50	7:51	7:50	7:53	8:01	7:49	7:48	7:47	8:06	8:07	8:08	8:05	Alton			
24																					
25																					
26	7:10	7:49	7:09	7:50	7:08	7:50	7:51	7:51	7:53	7:53	7:54	7:56	7:56	7:57	7:59	7:59	8:01	Alton			
27	7:11	7:31	7:09	7:31	7:09	7:32	7:32	7:33	7:34	7:35	7:36	7:38	7:39	7:41	7:40	7:44	7:46	Alton			
28	7:03	7:44	7:01	7:46	7:00	7:46	7:46	7:47	7:49	7:49	7:50	7:51	7:51	7:53	7:55	7:56	7:57	Alton			
29	7:09	7:45	7:07	7:46	7:06	7:46	7:47	7:48	7:49	7:50	7:51	7:53	7:54	7:55	7:56	7:58	8:00	Alton			
30																					
31																					

OS = Out of Service

2
of
2

Rainy River District School Board
 Rainy River High School - SFIS #9392 - Plumbing Installed 1958
 Water Flushing Procedure and Record Sheet - DWS 50011606

Rev 05-21-15

Flushing Procedure. Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily											Flushing
Month	10 Second Flush - Record Time Completed in Space											Completed By
Day	NW Hall Guidance) Fountains	Room 19/Guidance		Main Centre Washrooms		Room 4	Principal	Main Kitchen	Main Office	First Nation Counsel	Fountain	Name
		Main Room	Office bath	Boys	Girls						Fountain	
1	05	758	757	759	800	802	803	804	805	807	809	Christy
2	08	802	803	803	804	806	808	808	809	810	812	Christy
3	OS											
4	OS											
5	05	805	805	756	757	758	759	800	800	801	802	Allen W Adams
6	05	756	756	747	748	749	749	750	751	752	753	Allen W Adams
7	05	751	751	741	742	743	744	745	746	747	748	Allen W Adams
8	05	755	755	745	746	749	750	750	751	752	753	Allen W Adams
9	05	801	802	749	750	751	752	753	754	755	756	Allen W Adams
10	OS											
11	OS											
12	05	818	818	819	820	820	821	821	822	823	824	Christy
13	05	738	738	740	740	741	743	745	746	746	748	Christy
14	05	736	737	739	739	800	801	803	804	805	806	Christy
15	05	753	754	755	756	757	758	759	800	801	802	Christy
16	05	802	802	804	804	805	806	807	808	809	811	Christy
17	OS											
18	OS											
19	OS											
20	05	807	807	757	758	759	800	801	802	803	804	Allen W Adams
21	05	808	808	800	801	802	803	804	804	805	806	Allen W Adams
22	05	738	738	729	730	731	731	732	733	734	736	Allen W Adams
23	05	802	802	804	755	756	756	757	758	759	800	Allen W Adams
24	OS											
25	OS											
26	05	803	803	804	805	806	807	808	809	810	811	Christy
27	05	748	748	750	751	753	754	755	756	757	759	Christy
28	05	759	800	801	802	803	804	805	806	807	809	Christy
29	OS											
30	OS											

OS = Out of Service

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 50011605

Flushing Procedure: Any errors or omissions must be reported to the Manager of Plant Operations and Maintenance immediately. Do not modify this form without approval.
THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM WEEKLY FLUSHING MUST BE DONE ON MONDAYS

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sink's cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year
2018

Flushing Type: Daily **All times AM and recorded to the nearest minute. Ex. 7:46**

Principal

Day	5 Minute Flush				10 Second Flush										Record Time Completed in Space	Flushing Completed By Name			
	Girl's Changeroom (both sinks)		Boy's Washroom By Gym		Room 10 (west sink)		Rm 10 East	Rm 8	Rm 7 & Workroom	Accessible WR	Girls Gym Entry Washroom	Gym Entrance	Boys Changeroom	Staffroom			Rm 12	Rm 13	Library Workroom
	Start	End	Start	End	Start	End	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	Fountain	1 Sink	3 Sinks			2 Sinks	1 Sink	1 Sink
1	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
2	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
3	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
4	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
5	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
6	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
7	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
8	7:06	7:52	7:07	7:54	7:02	7:55	7:55	7:56	7:57	8:05	7:53	7:53	7:52	8:10	8:11	8:12	8:09	Allen W. [Signature]	
9	7:05	7:35	7:07	7:37	7:00	7:38	7:39	7:39	7:41	7:49	7:37	7:36	7:35	7:57	7:55	7:58	7:53	Allen W. [Signature]	
10	7:07	7:38	7:03	7:38	6:58	7:31	7:32	7:33	7:34	7:44	7:38	7:29	7:28	7:49	7:50	7:51	7:49	Allen W. [Signature]	
11	7:20	7:45	7:22	7:47	7:15	7:48	7:48	7:49	7:51	8:03	7:47	7:46	7:46	8:06	8:07	8:09	8:05	Allen W. [Signature]	
12	7:05	7:42	7:07	7:44	7:00	7:45	7:46	7:47	7:49	7:57	7:44	7:43	7:42	8:02	8:03	8:04	8:01	Allen W. [Signature]	
13	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
14	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
15	7:08	7:48	7:08	7:44	7:04	7:45	7:45	7:47	7:48	7:49	7:50	7:52	7:53	7:54	7:55	7:56	7:58	Chad [Signature]	
16	7:14	7:39	7:12	7:40	7:11	7:40	7:41	7:42	7:43	7:45	7:46	7:47	7:48	7:48	7:50	7:52	7:53	Chad [Signature]	
17	7:07	7:35	7:03	7:37	7:03	7:37	7:38	7:39	7:41	7:42	7:43	7:44	7:45	7:46	7:48	7:49	7:50	Chad [Signature]	
18	7:21	7:42	7:19	7:43	7:19	7:43	7:44	7:45	7:46	7:47	7:48	7:50	7:51	7:52	7:54	7:55	7:56	Chad [Signature]	
19	7:12	7:32	7:11	7:33	7:10	7:39	7:39	7:35	7:37	7:38	7:39	7:41	7:42	7:43	7:45	7:46	7:47	Chad [Signature]	
20	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
21	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
22	7:09	7:54	7:11	7:56	7:02	7:57	7:57	7:58	8:00	8:07	7:56	7:55	7:54	8:11	8:12	8:13	8:10	Allen W. [Signature]	
23	7:04	7:38	7:06	7:40	7:01	7:41	7:41	7:42	7:44	7:54	7:40	7:39	7:38	8:00	8:01	8:02	7:59	Allen W. [Signature]	
24	7:09	7:39	7:11	7:40	7:01	7:40	7:40	7:41	7:42	7:53	7:40	7:39	7:38	7:58	7:59	8:00	7:57	Allen W. [Signature]	
25	7:05	7:26	7:07	7:28	7:00	7:30	7:30	7:31	7:32	7:42	7:28	7:27	7:26	7:46	7:47	7:48	7:45	Allen W. [Signature]	
26	8:06	8:19	8:08	8:21	8:22	8:22	8:23	8:24	8:25	8:32	8:21	8:20	8:20	8:41	8:41	8:42	8:39	Allen W. [Signature]	
27	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
28	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
29	7:09	7:44	7:02	7:46	7:01	7:46	7:46	7:49	7:51	7:51	7:52	7:51	7:56	7:57	7:59	8:00	8:02	Allen W. [Signature]	
30	7:09	7:38	7:06	7:39	7:05	7:39	7:39	7:41	7:42	7:43	7:44	7:45	7:47	7:48	7:50	7:51	7:52	Allen W. [Signature]	
31	7:12	7:46	7:10	7:44	7:09	7:47	7:48	7:49	7:50	7:51	7:52	7:54	7:54	7:55	7:57	7:58	8:00	Allen W. [Signature]	

OS = Out of Service

2
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 500111606

Rev 05-21-15

Flushing Procedure. Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily											Flushing
Month	10 Second Flush - Record Time Completed in Space											Completed By
Day	NW Hall Guidance Fountains	Room 19/Guidance		Main Centre Washrooms		Room 4	Principal	Main Kitchen	Main Office	First Nation Counsel	Fountain	Name
	1 Sink	1 Sink	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	1 Sink	2 Sinks	2 Sinks	Fountain	
1	:	:	:	:	:	:	:	:	:	:	:	:
2	:	:	:	:	:	:	:	:	:	:	:	:
3	:	:	:	:	:	:	:	:	:	:	:	:
4	:	:	:	:	:	:	:	:	:	:	:	:
5	:	:	:	:	:	:	:	:	:	:	:	:
6	:	:	:	:	:	:	:	:	:	:	:	:
7	:	:	:	:	:	:	:	:	:	:	:	:
8	8:5	8:06	8:07	7:59	8:00	8:07	8:02	8:03	8:04	8:04	8:05	Allan W. Adams
9	0:5	7:50	7:51	7:42	7:43	7:43	7:44	7:45	7:45	7:46	7:47	Allan W. Adams
10	0:5	7:45	7:46	7:35	7:36	7:37	7:37	7:38	7:39	7:40	7:42	Allan W. Adams
11	0:5	8:03	8:03	7:52	7:52	7:53	7:54	7:55	7:55	7:56	7:58	Allan W. Adams
12	0:5	7:58	7:58	7:48	7:49	7:50	7:51	7:52	7:53	7:54	7:55	Allan W. Adams
13	:	:	:	:	:	:	:	:	:	:	:	:
14	:	:	:	:	:	:	:	:	:	:	:	:
15	0:5	7:49	8:00	8:01	8:02	8:03	8:03	8:05	8:06	8:07	8:09	Christina
16	0:5	7:57	7:56	7:59	8:00	8:01	8:02	8:04	8:05	8:06	8:08	Christina
17	0:5	7:53	7:52	7:55	7:56	7:57	7:59	8:00	8:01	8:02	8:04	Christina
18	0:5	7:58	7:58	8:00	8:00	8:02	8:03	8:04	8:05	8:06	8:08	Christina
19	0:5	7:51	7:50	7:52	7:53	7:55	7:56	7:57	7:57	8:00	8:02	Christina
20	:	:	:	:	:	:	:	:	:	:	:	:
21	:	:	:	:	:	:	:	:	:	:	:	:
22	0:5	8:08	8:08	8:01	8:01	8:02	8:03	8:04	8:04	8:05	8:06	Allan W. Adams
23	0:5	7:55	7:55	7:44	7:45	7:46	7:47	7:48	7:49	7:50	7:52	Allan W. Adams
24	0:5	7:54	7:55	7:44	7:45	7:46	7:47	7:48	7:49	7:50	7:51	Allan W. Adams
25	0:5	7:43	7:43	7:33	7:34	7:35	7:36	7:37	7:38	7:39	7:40	Allan W. Adams
26	0:5	8:37	8:38	8:26	8:27	8:28	8:29	8:30	8:31	8:32	8:33	Allan W. Adams
27	:	:	:	:	:	:	:	:	:	:	:	:
28	:	:	:	:	:	:	:	:	:	:	:	:
29	0:5	8:04	8:05	8:06	8:07	8:08	8:09	8:10	8:10	8:11	8:13	Christina
30	0:5	7:55	7:54	7:57	7:57	7:59	8:00	8:07	8:03	8:04	8:06	Christina
31	0:5	8:02	8:02	8:04	8:04	8:06	8:07	8:09	8:10	8:12	8:14	Christina

OS = Out of Service

1
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - IWS 500111605

Rev 05-21-15

Flushing Procedure: Any errors or omissions must be reported to the Manager of Plant Operations and Maintenance immediately. Do not modify this form without approval.
THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sink's cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only

Year 2017	Flushing Type: Daily		**All times AM and recorded to the nearest minute. Ex: 7:46**														Principal	Flushing Completed By	
	5 Minute Flush						10 Second Flush - Record Time Completed in Space												
Month Dec	Girl's Changeroom (both sinks)		Boy's Washroom By Gym		Room 10 (west sink)		Rm 10 East	Rm 8	Rm 7 & Workrooms	Accessible WR	Girls Gym Entry Washroom	Gym Entrance	Boys Changeroom	Staffroom	Rm 12	Room 13	Library Workroom	Name	
Day	Start	End	Start	End	Start	End	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	Fountain	1 Sink	3 Sinks	2 Sinks	1 Sink	1 Sink		
1	7:11	7:34	7:09	7:35	7:09	7:36	7:36	7:37	7:39	7:39	7:40	7:41	7:42	7:43	7:45	7:47	7:48	[Signature]	
2	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
3	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
4	7:06	7:17	7:09	7:53	7:03	7:53	7:54	7:55	7:56	7:57	8:00	8:01	8:01	8:03	8:04	8:05	8:07	[Signature]	
5	7:58	8:29	7:56	8:30	7:56	8:30	8:31	8:38	8:26	8:31	8:37	8:38	8:39	8:40	8:41	8:42	8:43	[Signature]	
6	7:35	7:53	7:19	7:54	7:18	7:54	7:55	7:56	7:57	7:58	8:01	8:02	8:03	8:04	8:05	8:06	8:07	[Signature]	
7	7:13	7:39	7:11	7:40	7:10	7:40	7:40	7:49	7:46	7:49	7:48	7:50	7:50	7:51	7:53	7:54	7:56	[Signature]	
8	7:13	7:46	7:10	7:47	7:09	7:48	7:48	7:49	7:51	7:51	7:52	7:51	7:55	7:56	7:57	7:58	8:00	[Signature]	
9	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
10	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
11	7:16	7:58	7:12	7:59	7:11	8:00	8:00	8:01	8:03	8:04	8:05	8:07	8:07	8:08	8:09	8:10	8:12	[Signature]	
12	7:07	7:38	7:08	7:39	7:05	7:39	7:39	7:41	7:40	7:43	7:44	7:45	7:46	7:47	7:48	7:49	7:51	[Signature]	
13	7:12	7:49	7:10	7:50	7:09	7:50	7:51	7:52	7:53	7:54	7:55	7:56	7:56	7:57	7:58	8:00	8:01	[Signature]	
14	7:11	7:34	7:07	7:35	7:06	7:35	7:36	7:37	7:39	7:39	7:44	7:42	7:43	7:44	7:48	7:48	7:50	[Signature]	
15	7:17	7:56	7:15	7:57	7:14	7:57	7:57	7:59	8:00	8:01	8:02	8:03	8:04	8:05	8:06	8:09	8:10	[Signature]	
16	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
17	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
18	7:08	7:48	7:10	7:50	7:04	7:51	7:51	7:52	7:54	8:08	7:50	7:49	7:48	8:10	8:11	8:13	8:09	[Signature]	
19	7:05	7:40	7:07	7:42	7:02	7:41	7:41	7:42	7:44	7:55	7:42	7:41	7:41	7:58	7:59	8:00	7:59	[Signature]	
20	7:05	7:40	7:08	7:41	7:00	7:42	7:42	7:43	7:45	7:57	7:41	7:46	7:40	8:00	8:01	8:02	7:59	[Signature]	
21	7:12	7:48	7:14	7:50	7:51	7:51	7:50	7:54	7:55	8:02	7:50	7:49	7:49	8:06	8:07	8:08	8:08	[Signature]	
22	7:04	7:21	7:06	7:26	7:00	7:27	7:27	7:29	7:29	7:38	7:26	7:25	7:24	7:44	7:45	7:46	7:45	[Signature]	
23	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
24	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
25	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
26	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
27	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
28	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
29	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
30	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
31	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	

OS = Out of Service

2
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 500111606

Rev 05-21-15

Flushing Procedure. Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.

(THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.

1. 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.

2. 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily											Flushing
Month	10 Second Flush - Record Time Completed in Space											Completed By
Day	NW Hall (Guidance) Fountains	Room 19 (Guidance)		Main Centre Washrooms		Room 4	Principal	Main Kitchen	Main Office	First Nation Counsel	Fountain	Name
		Main Room	Office bath	Boys	Girls							
1	7:51	7:52	7:52	7:51	7:55	7:56	7:57	7:58	7:59	8:00	8:01	Chetler
2												
3												
4	8:09	8:10	8:10	8:11	8:12	8:13	8:14	8:15	8:16	8:16	8:16	Chetler
5	8:45	8:45	8:46	8:47	8:47	8:49	8:49	8:50	8:51	8:52	8:53	Chetler
6	OS	8:09	8:09	8:10	8:11	8:12	8:13	8:14	8:14	8:15	8:17	Chetler
7	OS	7:58	7:57	7:59	8:00	8:01	8:02	8:03	8:04	8:05	8:06	Chetler
8	OS	8:02	8:01	8:03	8:04	8:05	8:06	8:07	8:08	8:09	8:10	Chetler
9												
10												
11	OS	8:14	8:04	8:15	8:16	8:17	8:18	8:19	8:20	8:21	8:22	Chetler
12	OS	7:53	7:53	7:55	7:55	7:56	7:57	7:59	8:00	8:00	8:00	Chetler
13	OS	8:03	8:02	8:04	8:05	8:06	8:07	8:08	8:09	8:10	8:12	Chetler
14	OS	7:53	7:52	7:54	7:55	7:56	7:57	7:58	7:59	8:00	8:01	Chetler
15	OS	8:12	8:12	8:13	8:14	8:15	8:16	8:17	8:17	8:18	8:19	Chetler
16												
17												
18	OS	8:08	8:08	7:55	7:56	7:57	7:58	7:59	8:00	8:02	8:04	Allen W. J. J.
19	OS	7:56	7:56	7:46	7:47	7:47	7:48	7:49	7:50	7:51	7:52	Allen W. J. J.
20	OS	8:02	8:03	7:47	7:48	7:49	7:50	7:51	7:52	7:53	7:54	Allen W. J. J.
21	OS	8:04	8:05	7:56	7:56	7:57	7:57	7:58	7:59	7:59	8:00	Allen W. J. J.
22	OS	7:40	7:41	7:29	7:30	7:31	7:32	7:33	7:34	7:35	7:36	Allen W. J. J.
23												
24												
25												
26												
27												
28												
29												
30												

OS = Out of Service

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 500111606

Rev 05-21-15

1
of
2

Flushing Procedure: Any errors or omissions must be reported to the Manager of Plant Operations and Maintenance immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 8.30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.

1. 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.

2. 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only

Year	Flushing Type: Daily																	Principal:		
2017	**All times AM and recorded to the nearest minute. Ex. 7:46**																			
Month	5 Minute Flush																	10 Second Flush - Record Time Completed in Space		Flushing
Nov	Girl's Changeroom (both sinks)		Boy's Washroom By Gym		Room 10 (west sink)		Rm 10 East	Rm 8	Rm 7 & Workroom	Accessible WR	Girls (sym) Entry Washroom	Gym Entrance	Pool Changer	Staffroom	Rm 12	Room 13	Library Workroom	Completed By		
Day	Start	End	Start	End	Start	End	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	Fountain	1 Sink	3 Sinks	2 Sinks	1 Sink	1 Sink	Name		
1	7:02	7:56	7:01	7:56	7:00	7:57	7:57	7:58	7:59	7:59	8:00	8:01	8:02	8:03	8:04	8:05	8:06	Allen Widat		
2	7:11	8:06	7:07	8:05	7:07	8:05	8:06	8:07	8:08	8:09	8:10	8:11	8:12	8:12	8:14	8:15	8:16	Allen Widat		
3	7:05	7:49	7:03	7:45	7:03	7:46	7:47	7:47	7:49	7:50	7:52	7:53	7:53	7:56	7:57	7:58	7:59	Allen Widat		
4	7:17	7:59	7:15	8:00	7:14	8:02	8:02	8:03	8:04	8:05	8:06	8:08	8:09	8:10	8:11	8:12	8:13	Allen Widat		
5																				
6																				
7	7:07	7:31	7:06	7:33	7:03	7:33	7:33	7:34	7:36	7:37	7:38	7:39	7:40	7:41	7:43	7:44	7:45	Allen Widat		
8	7:07	7:38	7:05	7:39	7:07	7:39	7:39	7:41	7:42	7:43	7:44	7:45	7:46	7:47	7:48	7:49	7:50	Allen Widat		
9	7:04	7:00	7:02	8:01	7:22	8:01	8:02	8:03	8:04	8:04	8:05	8:07	8:07	8:08	8:10	8:11	8:12	Allen Widat		
10	7:04	7:26	7:02	7:27	7:01	7:27	7:27	7:29	7:30	7:30	7:31	7:32	7:33	7:34	7:36	7:38	7:39	Allen Widat		
11																				
12																				
13	7:04	7:41	7:06	7:43	7:00	7:44	7:44	7:45	7:47	7:57	7:43	7:42	7:41	8:04	8:05	8:06	8:03	Allen Widat		
14	7:08	7:40	7:10	7:42	7:08	7:43	7:43	7:45	7:46	7:54	7:49	7:42	7:41	7:59	8:00	8:01	7:59	Allen Widat		
15	7:08	7:38	7:10	7:40	7:02	7:41	7:41	7:42	7:46	7:55	7:40	7:39	7:38	7:38	7:39	8:08	7:57	Allen Widat		
16	7:06	7:38	7:08	7:40	7:00	7:42	7:43	7:43	7:44	7:52	7:39	7:38	7:38	7:38	7:38	8:00	7:56	Allen Widat		
17	7:05	7:30	7:07	7:32	7:00	7:33	7:33	7:34	7:36	7:48	7:32	7:31	7:30	7:52	7:53	7:54	7:51	Allen Widat		
18																				
19																				
20	7:04	7:45	7:06	7:42	7:00	7:48	7:48	7:49	7:51	8:02	7:47	7:46	7:45	8:06	8:08	8:09	8:05	Allen Widat		
21	7:10	7:27	7:12	7:29	7:08	7:30	7:31	7:33	7:34	7:48	7:29	7:29	7:28	7:49	7:51	7:52	7:49	Allen Widat		
22	7:05	7:36	7:07	7:37	7:01	7:37	7:38	7:40	7:41	7:52	7:36	7:36	7:35	7:56	7:57	7:58	7:58	Allen Widat		
23	7:05	7:39	7:07	7:31	7:00	7:41	7:42	7:44	7:45	7:56	7:41	7:40	7:39	8:01	8:02	8:03	8:00	Allen Widat		
24	7:07	7:34	7:09	7:36	7:02	7:37	7:38	7:39	7:40	7:51	7:36	7:35	7:34	7:58	7:59	8:00	7:57	Allen Widat		
25																				
26																				
27	7:26	8:29	7:24	8:30	7:20	8:30	8:31	8:34	8:35	8:36	8:37	8:39	8:39	8:43	8:43	8:44	8:45	Allen Widat		
28	7:07	7:36	7:05	7:31	7:05	7:37	7:37	7:39	7:41	7:42	7:43	7:44	7:45	7:46	7:48	7:51	7:52	Allen Widat		
29	7:15	7:49	7:12	7:45	7:11	7:40	7:46	7:47	7:50	7:52	7:53	7:55	7:56	7:56	7:58	8:00	8:01	Allen Widat		
30	7:11	7:52	7:09	7:53	7:09	7:53	7:54	7:55	7:56	7:56	7:57	7:58	7:59	8:03	8:01	8:02	8:03	Allen Widat		
31																				

OS = Out of Service

2
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 50011606

Rev 05-21-15

Flushing Procedure. Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.

1. 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.

2. 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily											Flushing
Month	10 Second Flush - Record Time Completed in Space											Completed By
Day	NW Hall (Guidance) Fountains	Room 196 (Guidance) Main Room	Office bath	Boys	Girls	Room 4	Principal	Main Kitchen	Main Office	First Nation Counsel	Fountain	Name
1	8:08	8:09	8:09	8:10	8:11	8:12	8:13	8:13	8:14	8:15	8:16	Christ Jensen
2	8:18	8:18	8:18	8:19	8:20	8:21	8:21	8:22	8:22	8:23	8:24	Christ Jensen
3	8:02	8:03	8:04	8:05	8:05	8:07	8:08	8:08	8:09	8:10	8:12	Christ Jensen
4												
5												
6	8:15	8:16	8:16	8:06	8:06	8:17	8:18	8:19	8:20	8:21	8:22	Christ Jensen
7	7:47	7:48	7:47	7:49	7:49	7:51	7:52	7:53	7:54	7:55	7:57	Christ Jensen
8	7:52	7:53	7:53	7:55	7:56	7:59	7:59	8:00	8:01	8:02	8:04	Christ Jensen
9	8:13	8:14	8:14	8:15	8:16	8:17	8:18	8:19	8:20	8:24	8:26	Christ Jensen
10	7:40	7:41	7:41	7:42	7:43	7:44	7:45	7:46	7:47	7:48	7:49	Christ Jensen
11												
12												
13	8:00	8:01	8:01	7:50	7:51	7:52	7:53	7:54	7:55	7:56	7:57	Allen W. Jensen
14	7:55	7:56	7:56	7:47	7:48	7:49	7:50	7:51	7:52	7:52	7:53	Allen W. Jensen
15	7:56	7:57	7:57	7:47	7:48	7:49	7:50	7:51	7:51	7:52	7:53	Allen W. Jensen
16	7:53	7:54	7:54	7:42	7:43	7:44	7:45	7:46	7:46	7:47	7:48	Allen W. Jensen
17	7:49	7:50	7:50	7:38	7:39	7:40	7:41	7:42	7:43	7:44	7:46	Allen W. Jensen
18												
19												
20	8:03	8:04	8:04	7:52	7:53	7:53	7:54	7:55	7:56	7:56	7:58	Allen W. Jensen
21	7:46	7:47	7:47	7:36	7:37	7:38	7:39	7:40	7:40	7:41	7:43	Allen W. Jensen
22	7:53	7:53	7:53	7:44	7:45	7:46	7:46	7:47	7:48	7:49	7:50	Allen W. Jensen
23	7:56	7:57	7:57	7:46	7:47	7:48	7:50	7:50	7:51	7:52	7:53	Allen W. Jensen
24	7:52	7:53	7:53	7:48	7:48	7:43	7:44	7:45	7:46	7:47	7:48	Allen W. Jensen
25												
26												
27	8:48	8:48	8:48	8:49	8:50	8:51	8:51	8:52	8:54	8:54	8:55	Christ Jensen
28	7:54	7:55	7:55	7:56	7:57	7:58	7:59	8:00	8:03	8:04	8:05	Christ Jensen
29	8:03	8:04	8:04	8:06	8:06	8:07	8:08	8:09	8:10	8:11	8:13	Christ Jensen
30	8:05	8:06	8:05	8:07	8:08	8:09	8:10	8:11	8:11	8:12	8:14	Christ Jensen
31												

OS = Out of Service

1
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 500111606

Rev 05-21-15

Flushing Procedure: Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.

THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM WEEKLY FLUSHING MUST BE DONE ON MONDAYS

- 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
- 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only

Year	Month	Flushing Type: Daily		"All times AM and recorded to the nearest minute. Ex: 7:46"															Principal:	
		5 Minute Flush				10 Second Flush - Record Time Completed in Space														
SEP	Day	Girl's Changeroom (both sinks)		Boy's Washroom By Gym		Room 10 (west sink)		Rm 10 East	Rm 8	Rm 7 & Workroom	Accessible WR	Girls Gym Entry Washroom	Gym Entrance	Pave Changerm	Staffroom	Rm 12	Room 13	Library Workroom	Completed By	
		Start	End	Start	End	Start	End	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	Fountain	1 Sink	3 Sinks	2 Sinks	1 Sink	1 Sink	Name	
2017	1	7:05	7:27	7:07	7:29	7:00	7:29	7:30	7:31	7:33	7:45	7:29	7:28	7:27	7:50	7:51	7:52	7:52	7:49	Allan W. Adams
	2	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	3	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	4	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	5	7:37	7:42	7:38	7:43	7:39	7:44	7:44	7:45	7:46	7:47	7:48	7:49	7:50	7:51	7:52	7:53	7:54	7:54	Cliff Jensen
	6	7:15	7:27	7:14	7:26	7:14	7:25	7:25	7:29	7:30	7:31	7:32	7:33	7:34	7:35	7:37	7:38	7:39	7:39	Cliff Jensen
	7	7:08	7:14	7:06	7:15	7:06	7:16	7:17	7:18	7:19	7:19	7:20	7:22	7:22	7:23	7:25	7:26	7:28	7:28	Cliff Jensen
	8	7:10	7:16	7:09	7:14	7:06	7:14	7:14	7:18	7:19	7:19	7:20	7:22	7:22	7:23	7:24	7:25	7:26	7:26	Cliff Jensen
	9	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	10	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	11	7:05	7:40	7:07	7:43	7:01	7:44	7:44	7:45	7:47	7:57	7:43	7:42	7:41	7:59	8:00	8:02	7:58	7:58	Allan W. Adams
	12	7:05	7:27	7:07	7:30	7:00	7:31	7:31	7:32	7:33	7:43	7:29	7:29	7:28	7:48	7:49	7:50	7:47	7:47	Allan W. Adams
	13	7:03	7:22	7:05	7:24	7:00	7:25	7:26	7:27	7:29	7:31	7:24	7:23	7:22	7:42	7:43	7:44	7:41	7:41	Allan W. Adams
	14	7:05	7:33	7:07	7:35	7:01	7:35	7:36	7:39	7:38	7:50	7:35	7:34	7:33	7:55	7:56	7:57	7:54	7:54	Allan W. Adams
	15	7:03	7:26	7:05	7:28	6:58	7:27	7:30	7:31	7:33	7:44	7:28	7:27	7:26	7:50	7:51	7:52	7:49	7:49	Allan W. Adams
	16	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	17	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	18	6:58	7:35	6:57	7:37	6:57	7:38	7:38	7:39	7:40	7:41	7:42	7:43	7:45	7:46	7:47	7:48	7:49	7:49	Cliff Jensen
	19	7:13	7:43	7:10	7:44	7:10	7:44	7:45	7:46	7:47	7:47	7:48	7:49	7:49	7:50	7:51	7:52	7:51	7:51	Cliff Jensen
	20	7:11	7:47	7:08	7:44	7:08	7:44	7:51	7:51	7:52	7:53	7:53	7:54	7:55	7:56	7:57	7:58	7:59	7:59	Cliff Jensen
	21	7:01	7:32	7:00	7:34	6:59	7:34	7:35	7:36	7:36	7:37	7:38	7:39	7:41	7:41	7:43	7:44	7:45	7:45	Cliff Jensen
	22	7:05	7:39	7:03	7:40	7:03	7:41	7:42	7:43	7:44	7:44	7:45	7:46	7:47	7:48	7:50	7:51	7:52	7:52	Cliff Jensen
	23	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	24	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	25	7:04	7:40	7:07	7:42	7:00	7:43	7:43	7:45	7:46	7:58	7:42	7:41	7:40	8:03	8:04	8:06	8:02	8:02	Allan W. Adams
	26	7:04	7:28	7:06	7:30	7:01	7:30	7:31	7:32	7:33	7:41	7:30	7:29	7:29	7:46	7:47	7:48	7:45	7:45	Allan W. Adams
	27	7:05	7:20	7:07	7:22	7:00	7:23	7:23	7:24	7:25	7:36	7:22	7:21	7:20	7:41	7:42	7:43	7:40	7:40	Allan W. Adams
	28	7:05	7:34	7:06	7:36	7:02	7:36	7:37	7:38	7:40	7:52	7:36	7:36	7:35	7:57	7:58	8:00	7:56	7:56	Allan W. Adams
	29	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	30	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	
	31	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	:	

OS = Out of Service

2
of
2

Rainy River District School Board

Rainy River High School - SFIS #9392 - Plumbing Installed 1958
Water Flushing Procedure and Record Sheet - DWS 50011606

Rev 05-21-15

Flushing Procedure. Any errors or omissions must be reported to the Manager of Plant Operations and Mice immediately. Do not modify this form without approval.
THIS PROCEDURE MUST BE COMPLETED BEFORE 8:30AM. WEEKLY FLUSHING MUST BE DONE ON MONDAYS.
1. 5 Minute Flush: Turn on the cold water tap at the sink indicated for 5 minutes. Record the time the flush started and the time it ended. 5 min flush must be completed 1st.
2. 10 Second Flush: After 5 min flush, turn on each sinks cold water tap or run each fountain indicated for 10 seconds. Record the time that the flush was completed only.

Year	Flushing Type: Daily												Flushing
Month	All times AM and recorded to the nearest minute. Ex. 7:46"												Completed By
SEPT	10 Second Flush - Record Time Completed in Space												Name
	NW Hall (Guidance) Fountains	Room 19(Guidance)		Main Centre Washrooms		Room 4	Principal	Main Kitchen	Main Office	First Nation Counsel	Fountain	Completed By	
Day	1 Sink	1 Sink	1 Sink	2 Sinks	2 Sinks	1 Sink	1 Sink	1 Sink	2 Sinks	2 Sinks	Fountain	Name	
1	7:46	7:47	7:47	7:34	7:34	7:35	7:36	7:37	7:39	7:38	7:40	Allen W. Adams	
2	:	:	:	:	:	:	:	:	:	:	:		
3	:	:	:	:	:	:	:	:	:	:	:		
4	:	:	:	:	:	:	:	:	:	:	:		
5	7:57	7:57	7:58	7:39	8:00	8:01	8:02	8:02	8:03	8:04	8:06	Clint Jensen	
6	7:41	7:42	7:42	7:43	7:44	7:46	7:47	7:47	7:49	7:50	7:51	Clint Jensen	
7	7:30	7:31	7:30	7:32	7:33	7:34	7:35	7:36	7:37	7:38	7:39	Clint Jensen	
8	7:28	7:29	7:28	7:30	7:30	7:31	7:32	7:33	7:34	7:35	7:37	Clint Jensen	
9	7:	:	:	:	:	:	:	:	:	:	:		
10	:	:	:	:	:	:	:	:	:	:	:		
11	7:58	7:55	7:56	7:48	7:49	7:50	7:51	7:51	7:52	7:53	7:54	Allen W. Adams	
12	7:44	7:44	7:45	7:35	7:35	7:36	7:37	7:38	7:40	7:39	7:41	Allen W. Adams	
13	7:39	7:40	7:40	7:30	7:31	7:32	7:33	7:34	7:35	7:36	7:36	Allen W. Adams	
14	7:37	7:52	7:52	7:40	7:41	7:42	7:43	7:44	7:45	7:46	7:47	Allen W. Adams	
15	7:45	7:45	7:45	7:34	7:35	7:36	7:38	7:39	7:46	7:41	7:42	Allen W. Adams	
16	:	:	:	:	:	:	:	:	:	:	:		
17	:	:	:	:	:	:	:	:	:	:	:		
18	7:51	7:52	7:52	7:54	7:55	7:56	7:57	7:57	7:58	7:59	8:00	Clint Jensen	
19	7:56	7:57	7:56	7:58	7:58	7:59	8:00	8:01	8:01	8:02	8:03	Clint Jensen	
20	8:01	8:02	8:01	8:03	8:04	8:04	8:05	8:06	8:07	8:09	8:10	Clint Jensen	
21	7:47	7:48	7:48	7:49	7:50	7:51	7:52	7:54	7:55	7:55	7:56	Clint Jensen	
22	7:54	7:55	7:55	7:56	7:57	7:58	8:00	8:02	8:03	8:04	8:05	Clint Jensen	
23	:	:	:	:	:	:	:	:	:	:	:		
24	:	:	:	:	:	:	:	:	:	:	:		
25	7:59	7:59	7:59	7:49	7:50	7:51	7:52	7:53	7:54	7:54	7:55	Allen W. Adams	
26	7:42	7:42	7:43	7:32	7:33	7:34	7:35	7:35	7:36	7:37	7:37	Allen W. Adams	
27	7:38	7:38	7:39	7:28	7:28	7:29	7:30	7:30	7:31	7:32	7:33	Allen W. Adams	
28	7:53	7:53	7:53	7:43	7:44	7:44	7:45	7:46	7:47	7:48	7:50	Allen W. Adams	
29	:	:	:	:	:	:	:	:	:	:	:		
30	:	:	:	:	:	:	:	:	:	:	:		
31	:	:	:	:	:	:	:	:	:	:	:		

OS = Out of Service